



Office of Commissioner of
Insurance and Safety Fire
Protect | Enforce | Educate | Inform

JOHN F. KING
*Commissioner of Insurance
and Safety Fire*

Two Martin Luther King Jr. Drive
West Tower, Suite 702
Atlanta, Georgia 30334

BULLETIN 23-EX-5

TO: ALL OWNERS AND RESPONSIBLE PARTIES OF FREIGHT AND
PASSENGER ELEVATORS

FROM: JOHN F. KING
INSURANCE AND SAFETY FIRE COMMISSIONER

DATE: APRIL 17, 2023

RE: REGULATIONS PERTAINING TO EXISTING ELEVATOR DOOR LOCK
MONITORING

RULE: Rule 120-3-25-.15 Existing Installation (General)

- (9) All existing automatic passenger and freight elevators shall comply with **ASME A17.3 Section 3.10.12** within three (3) years of the effective date of this rule.

NOTICE OF CHANGE

Dear owner/user of elevators:

The Office of Insurance and Safety Fire has adopted **ASME Elevator Safety Code A17.3-2017, Safety Code for Existing Elevators and Escalators**. A part of this new Safety Code includes **Section 3.10 Operating Devices and Control Equipment, Requirement 3.10.12 System to Monitor and Prevent Automatic Operation of the Elevator with Faulty Door Contact Circuits**. All existing elevators in Georgia will be required to meet this requirement by January 1, 2025. You will need to reach out to a company that has a valid Class I Certificate of Authority to make sure you know what you will need to do to bring your equipment into compliance.

For inquiries contact Ben Crawford
Bcrawford@oci.ga.gov

JOHN F. KING
INSURANCE AND SAFETY FIRE COMMISSIONER
STATE OF GEORGIA