

**PROPOSED RULES
OF
OFFICE OF COMMISSIONER OF INSURANCE, SAFETY FIRE COMMISSIONER**

**CHAPTER 120-3
RULES OF SAFETY FIRE COMMISSIONER**

**SUBJECT 120-3-11.
RULES AND REGULATIONS FOR FLAMMABLE AND COMBUSTIBLE LIQUIDS
TABLE OF CONTENTS**

120-3-11-.06. Adopted Codes and Standards

Proposed Modification to 120-3-11-.06

120-3-11-.06

12. Delete subsection 9.5.1 in its entirety and substitute in its place the following:

“**9.5.1** Unattended self-service facilities shall be permitted to operate as long as such unattended self-service facilities are not open to the public while unattended self-service operations are being conducted. Unattended self-service operations shall be limited to proprietary and fleet fueling.”

Exception: Unattended self-service operations shall be allowed at any self-service station during a National Emergency or when the Governor has declared a state of emergency provided that the provisions of 9.5.2 through 9.5.6 and 9.5.9 through 9.5.11 are met.

13. Delete subsection 9.5.5 in its entirety and substitute in its place the following:

“**9.5.5** Each such location shall be provided with a public telephone to notify the fire department in the event of an emergency within 100 feet of the dispenser(s). Emergency phone numbers and contact points for owner/operator shall also be provided. The numbers shall be clearly visible to the user. “

14. Add a new subsection 9.5.7 to read as follows:

“**9.5.7** All dispensers are key or card controlled. For the purpose of this requirement, ~~a credit card is not defined as a card~~ proprietary cards and fleet fuel cards shall be required.”

15. Add a new subsection 9.5.8 to read as follows:

~~“9.5.8 Each key or card holder shall be fully trained in the safety operations and meet the requirements of a qualified attendant for such operation. The owner or operator of such station is responsible for the safe operation of the station and the training and documentation of training of all users thereof. “~~

16. Add a new subsection 9.5.9 to read as follows:

~~“9.5.9 Each such facility shall first apply for and have a valid self-service permit posted~~ have exterior emergency shutoff devices installed in accordance with section 6.7. Such shutoffs shall be clearly marked “Emergency Fuel Shutoff”. Such lettering shall be at least 1” high in red coloring on a white background.”

17. Add a new subsection 9.5.10 to read as follows:

~~“9.5.10 Dispensing equipment used at unattended self-service facilities shall be programmed or set to limit uninterrupted fuel delivery to 50 gallons.”~~

18. Add a new subsection 9.5.11 to read as follows:

~~“9.5.11 Each such facility shall have a valid self-service permit posted.”~~

Authority: O.C.G.A. Section 25-2-4, 25-2-16