

**RULES AND REGULATIONS OF
THE SAFETY FIRE COMMISSIONER
CHAPTER 120-3-3
STATE MINIMUM FIRE SAFETY STANDARDS
TABLE OF CONTENTS**

Section:

120-3-3-.04 (72) (g) modification to 2018 NFPA 101 Chapter 9

11. Add a new subparagraph 9.7.2.1.3

9.7.2.1.3 Where approved by the authority having jurisdiction valves on the exterior of buildings are permitted to be supervised by one of the following methods:

- (1) Valves locked in the correct position and inspected weekly as part of an approved procedure.
- (2) Valves located in a fenced enclosure under the control of the owner, sealed in the open position, and inspected weekly as part of an approved procedure.

9.7.2.1.3.1 Records shall be made for all inspections required by 9.7.2.1.3 (1) and (2) and shall be made available to the authority having jurisdiction upon request. These records shall be maintained for a period of 3 years.

9.7.2.1.3.2 The valve supervision methods described in 9.7.3.1.3 shall not apply to hospitals, hospices, ambulatory surgical centers, nursing homes, assisted living communities, assisted living homes, memory care units or other health care type occupancies or facilities that are regulated by the federal Centers for Medicare and Medicaid Services (CMS).

†† 12. Delete paragraph 9.9* in its entirety and substitute in its place the following:

9.9* Portable fire extinguishers shall be installed in all buildings, structures and facilities as set forth in this *Code* and as established in 906.1 of the *International Fire Code*, as adopted by Chapter 120-3-3 of the Rules and Regulations of the Safety Fire Commissioner. (Refer to **Table 1.4.4, CODES REFERENCE GUIDE**)

†† 13. Delete paragraph 9.10 in its entirety and substitute in its place the following:

9.10 Where required by either the provisions of another section of this *Code*, the *International Building Code (IBC)* as adopted by the Department of Community Affairs or the *International Fire Code (IFC)* as adopted by Chapter 120-3-3 Rules and Regulations of the Safety Fire Commissioner, standpipe and hose systems shall be provided in accordance with NFPA 14, Standard for the Installation of Standpipe and Hose Systems. Where standpipe and hose systems are installed in combination with automatic sprinkler systems, installation shall be in accordance with the appropriate provisions established by NFPA 13, *Standard for the Installation of Sprinkler Systems*, and NFPA 14, Standard for the Installation of Standpipe and Hose Systems.